

Long Beach Township Water and Sewer Cut and Cap requirements for inspection.

Pumps must be used for dewatering for cut and cap inspections.

Sewer

is to be cut and capped within 3ft of the roads edge (curb line)

If a cleanout is existing the cleanout can remain but needs to be cut down to a minimum 12in below grade. If this can not be done than the cleanout is to be removed

hard pvc (sch 35 or 40) are the only caps to be used to cap the sewer. A fernco can be used to attach the cap to our sewer.

A stake is to be placed in front of the cut sewer prior to backfill spray painted green.

Water

Is to be cut within 12in on the homeowner's side of our curb stop and the old pipe is to be removed from the stop.

Curb box is to be placed next to the curb stop not on the stop.

If there is a meter pit it can be cut on the homeowner's side of the pit. The pit must be visibly marked to prevent damage during construction of the dwelling. Curb stop is to be in the off position. Curb box before the pit is to be removed and placed next to the stop prior to backfill.

A stake is to be placed in front of the cut water service prior to backfill spray painted blue.

When you are ready for inspection call 609-361-1000 ext. 6671

It is recommended that on reconnection of the water and sewer that strong back fernco couplings be used on the sewer and all brass fittings be used on the water.

Water Meter- *****

Water meter and Node must be surrendered at time of Cut and Cap inspection to Long Beach Township Staff conducting inspection for approval. If meter pit exists, do not remove meter pit. Leave meter installed in meter pit.