

Annual Drinking Water Quality Report

Long Beach Township Water Department

North Beach

For the Year 2026, Results from the Year 2025

This report is designed to inform you about the quality of water and services we deliver to you every day. The North Beach Water System is supplied by the Surf City Water Department through a purchase agreement. The Surf City Water Department has three wells which draw their water from the Atlantic City Aquifer, over 500 feet deep. The New Jersey Department of Environmental Protection (NJDEP) has prepared and issued Source Water Assessment Reports and Summaries for all public water systems. The Source Water Assessment Report and Summary for the Surf City Water Department is available at <https://www.nj.gov/dep/watersupply/swap/index.html> or by contacting the NJDEP, Bureau of Safe Drinking Water at (609) 292-5550. You may also contact your public water system at (609) 492-6314. The Source Water Assessment Summary and Susceptibility Ratings for the Surf City Water System are included.

If you are a landlord, you must distribute this Drinking Water Quality Report to every tenant as soon as practicable, but no later than three business days after receipt. Delivery must be made by hand, mail, or email, and by posting the information in a prominent location at the entrance of each rental premises, pursuant to section #3 of NJ P.L. 2021, c.82 (C.58:12A-12.4 et seq.).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised people such as people with cancer undergoing chemotherapy, people who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Long Beach Township Water Department (North Beach) Test Results						
Public Water System ID # NJ1517003						
Contaminant	Violation Y/N	Level Detected	Units of Measurement	MC LG	MCL	Likely Source of Contamination
Inorganic Contaminants:						
Copper Test results Yr. 2024 Result at 90 th Percentile	N	0.22 No samples exceeded the action level. 11 samples. Range of detections: (ND – 0.435)	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits
Lead Test results Yr. 2024 Result at 90 th Percentile	N	2.7 No samples exceeded the action level. 5 samples. Range of detections: (ND – 8.35)	ppb	0	AL= 15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfection Byproducts:						
TTHM Total Trihalomethanes Test results Yr. 2025	N	Range = 3 - 5 Highest detect = 5	ppb	N/A	80	By-product of drinking water disinfection
HAA5 Haloacetic Acids Test results Yr. 2025	N	Range = 6 - 11 Highest detect = 11	ppb	N/A	60	By-product of drinking water disinfection
Regulated Disinfectants		Level Detected	MRDL		MRDLG	
Chlorine Test results Yr. 2025		Range = 0.3 – 2.0 ppm Average = 0.99 ppm	4.0 Ppm		4.0 Ppm	

Chlorine: Water additive used to control microbes

The Long Beach Township and the Surf City Water Departments routinely monitor for contaminants in your drinking water according to Federal and State laws. The tables show the results of that monitoring for the period of January 1 to December 31, 2025. The state allows us to monitor for some contaminants less than once per year, because the concentration of these contaminants does not change frequently. Therefore, some of our data, though representative, are more than one year old.

If you have any questions about this report, or concerning your water utility, please contact Michael Clark at 609-492-6314. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled Township Committee meetings at the municipal building 6805 Long Beach Boulevard, Brant Beach. Meetings are held on the first and third Friday of each month at 4:00 p.m.

Potential Sources of Contamination: The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or manmade. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Surf City Water Department Test Results Public Water System ID # NJ1531001						
Contaminant	Violation Y/N	Level Detected	Units of Measurement	MCL G	MCL	Likely Source of Contamination
Radioactive Contaminants						
Combined Radium 228 & 226 Test results Yr. 2024	N	Range = 1.5 Highest detect = 1.5	pCi/l	0	5	Erosion of natural deposits
Inorganic Contaminants:						
Barium Test results Yr. 2024	N	Range = 0.013 – 0.014 Highest detect = 0.014	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Copper Test results 1 st ½ of 2025 Result at 90 th Percentile	N	0.62 No samples exceeded the action level. 20 samples. Range of detections: (ND – 0.69)	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits
Copper Test results 2 nd ½ of 2025 Result at 90 th Percentile	N	0.33 No samples exceeded the action level. 20 samples. Range of detections: (ND – 0.34)	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits
Fluoride Test results Yr. 2024	N	Range = 0.1 Highest detect = 0.1	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Lead Test results 1 st ½ of 2025 Result at 90 th Percentile	N	4 No samples exceeded the action level. 20 samples. Range of detections: (ND – 4.6)	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Lead Test results 2 nd ½ of 2025 Result at 90 th Percentile	N	3.0 No samples exceeded the action level. 20 samples. Range of detections: (ND – 3.0)	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Disinfection Byproducts:						
TTHM Total Trihalomethanes Test results Yr. 2025	N	Range = 1 - 4 Highest detect = 4	ppb	N/A	80	By-product of drinking water disinfection
HAA5 Haloacetic Acids Test results Yr. 2025	N	Range = 4 - 5 Highest detect = 5	ppb	N/A	60	By-product of drinking water disinfection
Regulated Disinfectants		Level Detected	MRDL		MRDLG	
Chlorine Test results Yr. 2025		Range = 0.5 – 1.1 ppm Average = 0.8 ppm	4.0 ppm		4.0 ppm	

Chlorine: Water additive used to control microbes

DEFINITIONS

In the "Test Results" tables you may find some terms and abbreviations you might not be familiar with. To help you better understand these terms we have provided the following definitions:

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Action Level (AL) - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) -The "Goal" is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health.

MRDLG's do not reflect the benefits of the use of disinfectants to control microbial contamination.

MCL's are set at very stringent levels. To understand the possible health effects described for many regulated contaminants, a person would have to drink two liters of water every day at the MCL level for seventy years to have a one-in-a-million chance of having the described health effect.

Sources of Lead in Drinking Water

The Long Beach Township Water Department is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. Although most lead exposure occurs from inhaling dust or from contaminated soil, or when children eat paint chips, the U.S. Environmental Protection Agency (USEPA) estimates that 10 to 20 percent of human exposure to lead may come from lead in drinking water. Infants who consume mostly mixed formula can receive 40 percent to 60 percent of their exposure to lead from drinking water. Lead is rarely found in the source of your drinking water but enters tap water through corrosion, or wearing away, of materials containing lead in the water distribution system and household plumbing materials. These materials include lead-based solder used to join copper pipes, brass, and chrome-brass faucets, and in some cases, service lines made of or lined with lead. New brass faucets, fittings, and valves, including those advertised as "lead-free", may still contain a small percentage of lead, and contribute lead to drinking water. The law currently allows end-use brass fixtures, such as faucets, with up to 0.25 percent lead to be labeled as "lead free". However, prior to January 4, 2014, "lead free" allowed up to 8 percent lead content of the wetted surfaces of plumbing products including those labeled National Sanitation Foundation (NSF) certified. Visit the NSF website at www.nsf.org to learn more about lead-containing plumbing fixtures. Consumers should be aware of this when choosing fixtures and take appropriate precautions. When water stands in lead service lines, lead pipes, or plumbing systems containing lead for several hours or more, the lead may dissolve into your drinking water. This means the first water drawn from the tap in the morning, or later in the afternoon if the water has not been used all day, can contain fairly high levels of lead.

Steps You Can Take to Reduce Exposure to Lead in Drinking Water

For a full list of steps visit: <https://www.state.nj.us/dep/watersupply/dwc-lead-consumer.html>

Run the cold water to flush out lead. Let the water run from the tap before using it for drinking or cooking any time the water in the faucet has gone unused for more than six hours. The longer the water resides in plumbing the more lead it may contain. Flushing the tap means running the cold-water faucet. Let the water run from the cold-water tap based on the length of the lead service line and the plumbing configuration in your home. In other words, the larger the home or building and the greater the distance to the water main (in the street), the more water it will take to flush properly. Although toilet flushing or showering flushes water through a portion of the plumbing system, you still need to flush the water in each faucet before using it for drinking or cooking. Flushing tap water is a simple and inexpensive measure you can take to protect your health. It usually uses less than one gallon of water.

Use cold, flushed water for cooking and preparing baby formula. Because lead from lead-containing plumbing materials and pipes can dissolve into hot water more easily than cold water, never drink, cook, or prepare beverages including baby formula using hot water from the tap. If you have not had your water sampled or if you know, it is recommended that bottled or filtered water be used for drinking and preparing baby formula. If you need hot water, draw water from the cold tap and then heat it.

Do not boil water to remove lead. Boiling water will not reduce lead; however, it is still safe to wash dishes and do laundry. Lead will not soak into dishware or most clothes.

Use alternative sources or treatment of water. You may want to consider purchasing bottled water or a water filter. Read the package to be sure the filter is approved to reduce lead or contact NSF International at 800-NSF-8010 or www.nsf.org for information on performance standards for water filters.

Determine if you have interior lead plumbing or solder. If your home/building was constructed prior to 1987, it is important to determine if interior lead solder or lead pipes are present. You can check yourself, hire a licensed plumber, or check with your landlord.

Replace plumbing fixtures and service lines containing lead. Replace brass faucets, fittings, and valves that do not meet the current definition of "lead free" from 2014 (as explained above). Visit the NSF website at www.nsf.org to learn more about lead-containing plumbing fixtures.

Remove and clean aerators/screens on plumbing fixtures. Over time, particles and sediment can collect in the aerator screen. Regularly remove and clean aerators screens located at the tip of faucets and remove any particles.

Test your water for lead. Please call 609-492-6314 to find out how to get your water tested for lead. Testing is essential because you cannot see, taste, or smell lead in drinking water.

Get your child tested. Contact your local health department or healthcare provider to find out how you can get your child tested for lead if you are concerned about lead exposure. New Jersey law requires that children be tested for lead in their blood at both 1 and 2 years of age and before they are 6 years old if they have never been tested before or if they have been exposed to a known source of lead.

Have an electrician check your wiring. If grounding wires from the electrical system are attached to your pipes, corrosion may be greater. Check with a licensed electrician or your local electrical code to determine if your wiring can be grounded elsewhere. DO NOT attempt to change the wiring yourself because improper grounding can cause electrical shock and fire hazards.

Water softeners and reverse osmosis units will remove lead from water but can also make the water more corrosive to lead solder and plumbing by removing certain minerals; therefore, the installation of these treatment units at the point of entry into homes with lead plumbing should only be done under supervision of a qualified water treatment professional.

Health Effects of Lead

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Long Beach Township (North Beach) Water Department is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, call Mike Clark at 609-492-6314. For information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Exposure to lead in drinking water can cause serious health effects in all age groups. Infants and children can have decreases in IQ and attention span. Lead exposure can lead to new learning and behavior problems or exacerbate existing learning and behavior problems. The children of women who are exposed to lead before or during pregnancy can have increased risk of these adverse health effects. Adults can have increased risks of heart disease, high blood pressure, kidney or nervous system problems.

In July 2021, P.L.2021, Ch.183 (Law) was enacted, requiring all community water systems to replace lead service lines in their service area within 10 years. Under the law, The Long Beach Township Water Department is required to notify customers, non-paying consumers, and any off-site owner of a property (e.g., landlord) when it is known they are served by a lead service line*. Our service line inventory is available upon request.

The Safe Drinking Water Act regulations allow monitoring waivers to reduce or eliminate the monitoring requirements for asbestos, volatile organic chemicals and synthetic organic chemicals. The Surf City Water Department received a monitoring waiver for synthetic organic contaminants. The Surf City Water Department is on reduced monitoring once every three years for Inorganic compounds. To ensure the continued quality of their water, they treat it in several ways. They use sodium-hypo chloride for disinfection, caustic soda for Ph adjustment and potassium permanganate for iron and manganese removal.

We at Long Beach Township Water Department work hard to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Please call our office if you have questions.

Surf City Water Department-PWSID # NJ1531001

Surf City Water Department is a public community water system consisting of 3 wells.

This system’s source water comes from the following aquifer: Kirkwood-Cohansey Water Table Aquifer System.

This system can purchase water from the following water systems: Ship Bottom Water Department, Harvey Cedars Water Department.

Susceptibility Ratings for Surf City Water Department Sources

The table below illustrates the susceptibility ratings for the seven contaminant categories (and radon) for each source in the system. The table provides the number of wells and intakes that rated high (H), medium (M), or low (L) for each contaminant category. For susceptibility ratings of purchased water, refer to the specific water system’s source water assessment report.

The seven contaminant categories are defined at the bottom of this page. DEP considered all surface water highly susceptible to pathogens, therefore all intakes received a high rating for the pathogen category. For the purpose of Source Water Assessment Program, radionuclides are more of a concern for ground water than surface water. As a result, surface water intakes’ susceptibility to radionuclides was not determined and they all received a low rating.

If a system is rated highly susceptible for a contaminant category, it does not mean a customer is or will be consuming contaminated drinking water. The rating reflects the potential for contamination of source water, not the existence of contamination. Public water systems are required to monitor for regulated contaminants and to install treatment if any contaminants are detected at frequencies and concentrations above allowable levels. As a result of the assessments, DEP may customize (change existing) monitoring schedules based on the susceptibility ratings.

Sources	Pathogens			Nutrients			Pesticides			Volatile Organic Compounds			Inorganics			Radionuclides			Radon			Disinfection Byproduct Precursors		
	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L
Wells - 3			3			3			3			3			3			3			3	3		

Pathogens: Disease-causing organisms such as bacteria and viruses. Common sources are animal and human fecal wastes.

Nutrients: Compounds, minerals and elements that aid growth, that are both naturally occurring and man-made. Examples include nitrogen and phosphorus.

Volatile Organic Compounds: Man-made chemicals used as solvents, degreasers, and gasoline components. Examples include benzene, methyl tertiary butyl ether (MTBE), and vinyl chloride.

Pesticides: Man-made chemicals used to control pests, weeds and fungus. Common sources include land application and manufacturing centers of pesticides. Examples include herbicides such as atrazine, and insecticides such as chlordane.

Inorganics: Mineral-based compounds that are both naturally occurring and man-made. Examples include arsenic, asbestos, copper, lead, and nitrate.

Radionuclides: Radioactive substances that are both naturally occurring and man-made. Examples include radium and uranium.

Radon: Colorless, odorless, cancer-causing gas that occurs naturally in the environment. For more information go to <http://www.nj.gov/dep/rpp/radon/index.htm> or call (800) 648-0394.

Disinfection Byproduct Precursors: A common source is naturally occurring organic matter in surface water. Disinfection byproducts are formed when the disinfectants (usually chlorine) used to kill pathogens react with dissolved organic material (for example leaves) present in surface water.

Important Information About Our Drinking Water

Special Notice:

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During **01/01/2023 – 12/31/2025**, we did not monitor for **Volatile Organic Chemicals (VOC)** at sample point ID: TP003009 Well 6 Treatment Plant and TP001003 Well 7 Treatment Plant and therefore cannot be sure of the quality of your drinking water during that time. The system has implemented new procedures to ensure on time submission of water quality parameter data to the NJDEP.

All water systems must provide a notice of the individual tap results from Lead Tap Monitoring to the people served by the water system at the specific sampling site from which the sample was taken. This notice must be provided no later than 30 days after learning of the tap monitoring results. Surf City Water Department was late with these notices from the 1st ½ and the 2nd ½ of the 2024 monitoring events.

Unregulated Contaminant Monitoring Rule (UCMR5)

The Surf City Water Department participated in UCMR5 in 2023. Unregulated contaminants are those for which the EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist the EPA in determining the occurrence of unregulated contaminants in drinking water and whether regulation is warranted. Our results are available upon request.

Lithium was detected above the Minimum Reporting Level (MRL) of 9 ppb. **Lithium** is a naturally occurring element. Levels reported were 11 – 13 ppb. Average of 12 ppb.

Minimum Reporting Level (MRL)” is defined as the smallest measured concentration of a substance that can be reliably measured by using a given analytical method.

For more information about reporting levels and screening levels for lithium in drinking water, go to [Technical Fact Sheet: Lithium in Drinking Water \(epa.gov\)](#).

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.